


Building Certificate


The School building of D.A.V Public School Greyoh Tehsil Dharampur DISTT. MANDI (H.P.) was inspected by me with the concerned Junior Engineer. As per report of the Junior Engineer this building has neither been designed nor constructed by this office. No earthquake resistant norms have been adopted for this building. No Structural drawing approved by the competent Government agency have been produced. The structure is a Non Engineering structure. Hence the structural safety of this building can't be ensured specially from Earthquake point of view. This building has been constructed in the year 2006 (Block-I) 2011 (Block-II) and in 2018 (Block -III). The department will not be responsible for any type of loss of life and property etc. if this structure fails under any circumstances. However as per visual inspection the building has been found to be safe for the session 2026-27.

Dated:-03.02.2026

Place: Greyoh


Junior Engineer,
Tihra Section
HP.PWD Tihra


Assistant Engineer
Tihra Sub Division
HP.PWD Tihra


Executive Engineer,
B&R Division,
HP.PWD Dharampur